

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21276

1. OWNER Robert Ohl ADDRESS AT WELL LOCATION 8 Thurston way  
 MAKING ADDRESS P.O. Box 41 Yerington NV 89442  
Smith NV 89430  
 2. LOCATION SE 1/4 NW 1/4 Sec. 9 T. 13 N. R. 26 E. Lpn County  
 PERMIT NO. 14-601-42 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other muo

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	5	5
Coarse Sand - Gravel				
Rock		5	8	3
Brown Clay		8	10	2
Coarse Sand - Gravel				
Rock		10	18	8
Coarse Sand - Gravel				
Clay		18	25	7
Coarse Sand - Gravel		25	35	10
Clay - Coarse Sand		35	48	13
Clay - Coarse Sand - Gravel				
Gravel		48	56	8
Coarse Sand - Gravel		56	78	22
Clay - Coarse Sand		78	84	6
Coarse Sand - Gravel		84	98	14
Coarse Sand - Gravel				
Rock	X	98	139	41

8. WELL CONSTRUCTION  
 Depth Drilled 139 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 139 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>12.92</u>	<u>1.88</u>	<u>71</u>	<u>139</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 7 3/4 x 3" 6 Rows  
 From 117 feet to 139 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 139 feet

9. WATER LEVEL  
 Static water level 41' 6" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 12-6, 1994  
 Date completed 12-9, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>20</u>	<u>3' 6"</u>	<u>1 HR</u>
<u>AIR LIFT</u>	<u>50</u>	<u>120' Line</u>	<u>1 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cyden Baw Drilling Contractor  
 Address 162 N. B. Bee Ln Contractor  
Yerington NV 89442  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Larry Guba  
 By driller performing actual drilling on site or contractor  
 Date 6-26-99