WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77019
Permit No.
Basin 179

NOTICE OF INTENT NO. 40194

1. OWNER REED DIST. INC.
MAILING ADDRESS 807 AVENUE F
ELY, NV 89301

ADDRESS AT WELL LOCATION REED R-PLACE SHELL STATION AT 909 AVENUE F, ELY NY

2. LOCATION SE 1/4 NW 1/4 Sec. 16 T 16N N/S R 63E E WHITE PINE County
PERMIT NO. WELL NO. MW-11 (Issued by Water Resources) | 2-055-00-7 (Parcel No.) | TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
ASPHALT		0	.2	
FILL MATERIAL		.2	3	2.8
MED-COARSE SAND &	X	3		
GRAVEL			85	82

PLACED 6' OF 3/8" BENTONITE ABOVE SAND FROM 44-50'
PUMPED CEMENT/BENTONITE SLURRY FROM 12-44'
CEMENTED IN FLUSH MOUNT MONUMENT AT SURFACE

Date started 1/8/99 , 19__
Date completed 1/9/99 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5		.5

8. **WELL CONSTRUCTION**
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	10	Feet
8 1/2	Inches	10	Feet	85	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	SCH 80	.3	85

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 55 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 12
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 85 feet

9. **WATER LEVEL**
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed J. Craig Sirs (By driller performing actual drilling on-site or contractor)
Date 1/14/99

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED 99 JAN 26 AM 11:56 STATE ENGINEER'S OFFICE