WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77023
Permit No.
Basin 104

NOTICE OF INTENT NO. 42881

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS Carson City, NV.

ADDRESS AT WELL LOCATION
#60 Arrowhead Dr.
Carson City, NV.

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 15 N/S R. 20 E. Carson City County
PERMIT NO. (Issued by Water Resources) 08-052-08 (Parcel No.) Eagle Valley Vista (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at a depth of 32.23'. Depth of well @ 94'. Installed tremme pipe and air lifted debris from well until we reached hard bottom at a depth of 96.3'. Installed 6" Mills Knife and perforated 4 slots per foot from 76' to surface. Removed perforator and installed tremme pipe to bottom of well. Mixed 26 bags of Portland Type II cement and approx. 150 gal. of water. Cement was pumped through tremme pipe from the bottom of the well to the surface.				

Date started 9/24, 19 99
Date completed 9/24, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 96.3' Feet

HOLE DIAMETER (BIT SIZE)
From To
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	+1	96'

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 96'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 32.23' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 39920

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed ____ (By driller performing actual drilling on site or contractor)

Date October 2, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627