

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25128

1. OWNER F. W. Hanson ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 600 Hwy 95-A East  
Yerington NV 89447  
 2. LOCATION NW 1/4 NW 1/4 Sec 2 T 13 N S R 26 E Lyon County  
 PERMIT NO. 14-652-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	10	10
Coarse Sand - Small				
Gravel - Few Rock		10	85	75
Brown clay - Gravel		85	90	5
Coarse Sand - Gravel - Clay Stratas		90	128	38
Brown clay - Gravel		128	148	20
Coarse Sand - Gravel - Few Rock	X	148	180	32
Coarse Sand - Gravel - Rock	X	180	199	19

8. WELL CONSTRUCTION  
 Depth Drilled 199 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 3/4 Inches To 19 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>71</u>	<u>200</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 2 1/2" x 8 Rows  
 From 15 1/2 feet to 17 1/2 feet  
 From 18 1/2 feet to \_\_\_\_\_ feet  
 From 17 1/2 feet to 19 1/2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 199 feet

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N Bybee Ln  
Yerington NV 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Lg Ogden  
 By driller performing actual drilling on site or contractor  
 Date 6-29-99

Date started 11-1 1995  
 Date completed 11-3 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>20</u>	<u>5</u>	<u>1 HR</u>

RECEIVED  
 50 JUN 30 AM 11:55  
 STATE ENGINEERING OFFICE