WHITE—DIVISION OF WATER RESOURCES B-3
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77040
Permit No.
Basin 212

NOTICE OF INTENT NO. 19013

1. OWNER Tosco Corporation
MAILING ADDRESS 3550 N. Central Ave 4th floor Phoenix, Arizona 85012
ADDRESS AT WELL LOCATION Unocal Store #4370 3758 South Las Vegas Boulevard Las Vegas, Nevada

2. LOCATION SE ¼ SE ¼ Sec 20 T 21 N/S R 61 E Clark County
PERMIT NO. Issued by Water Resources | 162-20-701-012 Parcel No. | Subdivision Name

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt underlain by light brown silty sand, road fill, contains gravels		0	8	
Clayey sand, pre-dominantly coarse sand grains contains		8	16	
Clayey sand very cohesive, predomin contains fine grained materials		16	24	
Clayey sand, very damp, highly cohesive fine-coarse grained sand, no gravels, yellowish gray, very still-hard		24	30	

OCT 26 1999

Date started 9.15 1999
Date completed 9.15 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 30 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	15

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 4
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 4 feet to 30 feet

9. WATER LEVEL
Static water level 21.06 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc (Contractor)
Address 301 West Deer Valley Road #7 Phoenix, Arizona 85027 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070T1
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/19/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627