WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 770441
Permit No.
Basin 212

NOTICE OF INTENT NO. 19013

1. OWNER Tosco Marketing Company
MAILING ADDRESS 3550 North Central Ave 4th floor, Phoenix, Arizona 85012
ADDRESS AT WELL LOCATION Unocal Store # 4370 3758 South las Vegas Boulevard Las Vegas, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 20 T 21 N/S R 61 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-20-701-012 | Subdivision Name

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt underlain by a sandy gravel fill damp, moderat yellowish brown, well graded coarse sand		0	6	
Sandy clay w/ gravels, damp, pale yellowish, brown, well coarsed sand, very stiff		6	11	
Sand, damp, dark yellowish orange, very dense		11	16	
Sandy clay w/ trace gravel, damp pale yellowish brown med-fine sand, very stiff		16	20	
Increasing gravels and size		20	22	
Caliche, slightly damp, gravelly clay w/ some sand, moist,		22	25	
			OCT 26 1999	

Date started 9.16 1999
Date completed 9.16 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air-Lift

G.P.M.	Draw-Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	15

Perforations:
Type perforation Sch 40 PVC
Size perforation 020
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 14
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 14 feet to 35 feet

9. WATER LEVEL
Static water level ~27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc
Contractor
Address 301 West Deer Valley Rd #7
Contractor
Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070T1
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10/18/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627