WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PRB-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77045
Permit No.
Basin 212

NOTICE OF INTENT NO. 19012

1. OWNER Tosco Marketing Company
MAILING ADDRESS 1500 North Priest Ave
Tempe, Arizona 85281

ADDRESS AT WELL LOCATION Circle K #3846
2300 Las Vegas Boulevard
Las Vegas, Nevada 89119

2. LOCATION SE ¼ SE ¼ Sec. 4 T. 21 S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) 162-03-410-006 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other:

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other ASA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt underlain w/ sandy gravel		0	6	
Sandy Clay w/ gravels damp, dark brown, med coarse sand				
Clayey sand w/ gravels, damp, dark yellowish orange, well graded med coarse sand		6	11	
Gravelly Clay w/ some sand, moist, pale yellowish brown, coarse sands, very stiff		11	13	
Clay with some sand, gravels, wet light brown, gravel, fine sand		13	15	
Increasing gravel and size, subrounded gravels		15	18	
Same - a lot of H_2O		18	25	

OCT 26 1999

Date started 9.16, 1999
Date completed 9.16, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 10 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	20

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 9
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 9 feet to 25 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc (Contractor)
Address 201 W. Deer Valley Rd #17 (Contractor)
Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 4809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M007071
Signed Danny Gomez (By driller performing actual drilling on site or contractor)
Date 10/19/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627