WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

HH-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77046
Permit No.
Basin 212

NOTICE OF INTENT NO. 19012

1. OWNER Tosco Marketing Company
MAILING ADDRESS 1500 North Priest Drive Tempe, Arizona 85281
ADDRESS AT WELL LOCATION Circle K # 3846 2306 Las Vegas Boulevard Las Vegas, Nevada 89119

2. LOCATION SE ¼ SE ¼ Sec 4 T 21 N/S R 61 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-03-410-006 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt underlain by a silty gravel fill material, damp, dark brown, sandy clay light brown, trace gravels		0	6	
Clayey sand w/ some gravels, dry, pale yellowish brown, crystals, well graded coarse sand, med dense decreasing sands		6	11	
Sandy clay w/ gravels, moist, pale yellowish brown, well graded med. fine sand, very stiff		11	15	
decreasing sand, gravelly clay, pale yellowish brown, wet		15	20	

Date started 9.16, 1999
Date completed 9.16, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 10 Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 20 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	10

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 9
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 9 feet to 20 feet

9. WATER LEVEL
Static water level 2.12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies Inc
Contractor
Address 301 W. Deer Valley Rd #7
Contractor
Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070T1
Signed Larry Lopez
By driller performing actual drilling on site or contractor
Date 10/19/99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627