


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. **77056**
 Permit No.
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18904

1. OWNER **AVCO/Heritage B**
 MAILING ADDRESS **5880 E. Santovito**
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
5880 E. Santovito

2. LOCATION **SW 1/4 SW 1/4 Sec. 15 T 21S**
 PERMIT NO. **43-101-11**
 Issued by Water Resources Parcel No.

N/S R **54E** E **Nye County** County

Cottonwoods Subdivision Name

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay with gravel		0	13	13
brown caleche with rock		13	41	28
See next line	x	41	82	41
brown clay with caleche strings				
See next line	x	82	124	42
brown clay with gravel and caleche strings				
brown clay and rock	x	124	135	11
brown caleche	x	135	160	25

8. WELL CONSTRUCTION

Depth Drilled **160** Feet Depth Cased **160+1** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
Inches	0	160	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:

Type perforation **sawcut**
 Size perforation **.188**
 From **135** feet to **160** feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **160** feet

9. WATER LEVEL

Static water level **62** feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **8/12/99**
 Date completed **8/12/99**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor

Address **2301 Winery Road, Suite 2** Contractor

Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor

Date **8.28.99**