


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. **77078**  
 Permit No.  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18856

1. OWNER **Jerry & LaDonna Maddy**  
 MAILING ADDRESS **3091 S. Woodchips**  
**Pahrump, NV 89048**

ADDRESS AT WELL LOCATION  
**3091 S. Woodchips**

2. LOCATION **SE 1/4 NE 1/4 Sec. 18 T 20S**  
 PERMIT NO. **36-172-13**  
 Issued by Water Resources Parcel No.

**N/S R 53E E Nye** County  
 Subdivision Name

3. **WORK PERFORMED**

New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other  Municipal/Industrial

4. **PROPOSED USE**

Irrigation  Test  Cable  
 Monitor  Stock  Air

5. **WELL TYPE**

Rotary  RVC  
 Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
brown loam soil		0	12	12
brown clay with caleche		12	26	14
See next line	x	26	82	56
brown clay with grey caleche strings				
brown clay and grey clay	x	82	140	58

8. **WELL CONSTRUCTION**

Depth Drilled **140** Feet Depth Cased **140+1** Feet

**HOLE DIAMETER (BIT SIZE)**

	From	To	
Inches	0	140	Feet
Inches			Feet
Inches			Feet

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

**Perforations:**

Type perforation **sawcut**  
 Size perforation **.188**

From <b>115</b>	feet to <b>140</b>	feet
From	feet to	feet

Surface Seal:  Yes  No

Seal Type:

Depth of Seal **50**

Neat Cement

Placement Method:  Pumped

Cement Grout

Poured

Concrete Grout

Gravel Packed:  Yes  No

From **50** feet to **140** feet

9. **WATER LEVEL**

Static water level **45** feet below land surface

Artesian flow  G.P.M.  P.S.I.

Water temperature **cool** °F Quality **good**

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.**  
 Contractor

Address **2301 Winery Road, Suite 2**  
 Contractor

**Pahrump, NV 89048**

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor

Date **8.28.99**

Date started **8/26/99** 19\_\_  
 Date completed **8/26/99** 19\_\_

7. **WELL TEST DATA**

TEST METHOD:  Bailer  Pump  Air Lift  
 G.P.M.  Draw Down (Feet Below Static)  Time (Hours)

001 25