

8-177-188  
14 x 8

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 77088  
Permit No. \_\_\_\_\_  
Basin 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19907

1. OWNER Catherine Duckett ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS P.O. Box 2983 1571 W. Chukar St.  
Pahrump, NV 89041 Pahrump, NV 89048  
2. LOCATION SE 1/4 SE 1/4 Sec 8 T. 20S N/S R. 53E E Nye County  
PERMIT NO. 36-111-01 36-111-01 Chapparrel Ranchos, Lot 1  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material         | Water Strata | From | To  | Thick-ness |
|------------------|--------------|------|-----|------------|
| Surface          |              | 0    | 4   | 4          |
| Grey Clay        |              | 4    | 14  | 10         |
| Brown Clay       |              | 14   | 56  | 42         |
| Tan Colored Clay | x            | 56   | 86  | 30         |
| Brown Clay       | x            | 86   | 160 | 74         |

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
12 Inches 0 Feet 160 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8"                 | 17#                 | .188                    | 0           | 160       |

Perforations:  
Type perforation torch cut  
Size perforation 1/2" x 8"  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 120 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50' feet to 160' feet

9. WATER LEVEL  
Static water level 58 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 10-22-99 19\_\_\_\_  
Date completed 10-13-99 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 15     | -0-                           | 15 min       |

Name Charles Nyberg Well Drilling Contractor  
Address 1060 W. Basin Rd Contractor  
Pahrump, NV 89041  
Nevada contractor's license number issued by the State Contractor's Board 7484  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
Signed Charles Nyberg by CSD  
By driller performing actual drilling on site or contractor  
Date 10-21-99

