WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77090
Permit No.
Basin 162

NOTICE OF INTENT NO. 18805

1. OWNER Henry Sanchez
MAILING ADDRESS 1230 Hinson St
Las Vegas, NV 89102

ADDRESS AT WELL LOCATION
571 N Woodchips
Pahrump, NV 89048

2. LOCATION SW ¼ SW ¼ Sec. 7 T. 20S N/S R. 53E E. Nye County
PERMIT NO. 36-161-39 Issued by Water Resources | 36-161-39 Parcel No. | Sanchez parceling Lot 2 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey Clay		4	18	14
Soft brown clay		18	48	30
Hard strip (clay)		48	56	8
Soft brown clay	x	56	94	38
Hard clay		94	118	24
Brown clay	x	118	160	42

DCNR/DWR Received OCT 27 1999 LAS VEGAS OFFICE

Date started 10-4-99, 19
Date completed 10-5-99, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	160 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	160

Perforations:
Type perforation torch cut
Size perforation ¼" wide x 8" long
From feet to feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by CRO (By driller performing actual drilling on site or contractor)
Date 10-21-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627