WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77105
Permit No.
Basin 212

NOTICE OF INTENT NO. 16824

1. OWNER Robert Walsh
MAILING ADDRESS 333 S. 3rd St. LV, NV 89101
ADDRESS AT WELL LOCATION 116 Garces Ave + 704 Casino Center Blvd.

2. LOCATION NW ¼ SW ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 139-34-310-033+034 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Sand | | 0 | 6 | 6 |
| Clayey Sand | | 6 | 7 | 1 |
| Caliche | | 7 | 11 | 4 |
| Sandy clay | | 11 | 13 | 2 |
| Caliche | | 13 | 22 | 9 |
| MW-2 | | | | |

DCNR/DWR Received OCT 27 1999 LAS VEGAS OFFICE

Date started 6-23, 1999
Date completed 6-23, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 20.5 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 6 | 0 | 22 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | | 0 | 20.5 |
| | | | | |

Perforations:
Type perforation slotted
Size perforation .010
From 5.7 feet to 20.3 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 2 feet to 22 feet

9. WATER LEVEL
Static water level 9.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed (By driller performing actual drilling on site of contractor)
Date 10/25/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627