WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77109
Permit No.
Basin 108

NOTICE OF INTENT NO. 25127

1. OWNER Richard Wallack
MAILING ADDRESS P.O. Box 20032 Reno NV 89570
ADDRESS AT WELL LOCATION 38 N Bybee Ln Yerington NV 89447

2. LOCATION SW ¼ NW ¼ Sec. 9 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 14-371-24 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sand		0	3	3
Coarse Sand - Gravel		3	12	9
Coarse Sand - Gravel - Rock		12	25	13
Rock - Coarse Sand - Gravel		25	38	13
Clay - Sand - Gravel		38	41	3
Sand - Gravel - Rock		41	44	3
Coarse Sand - Gravel		44	61	17
Clay - Sand - Gravel		61	72	11
Coarse Sand - Gravel		72	84	12
Clay - Sand - Gravel		84	130	46
Coarse Sand - Gravel		130	146	16
Clay - Sand - Gravel		146	162	16
Coarse Sand - Gravel		162	170	8
Clay - Sand - Gravel		170	172	2
Coarse Sand - Gravel		172	176	4
Clay - Coarse Sand - Gravel		176	184	8
Coarse Sand - Gravel - Clay Strata		184	198	14
Clay - Coarse Sand		198	228	30
Coarse Sand - Gravel - Few Rock	X	228	249	21

Date started 10-10, 1985
Date completed 10-13, 1985

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	8	1 HR
AIR LIFT	30	220 line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 249 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	249 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	250

Perforations:
Type perforation Sawed
Size perforation 3/32 X 3" X 6 Rows
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 249 feet

9. WATER LEVEL
Static water level 99 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden (By driller performing actual drilling on site or contractor)
Date 6-29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627