WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7110
Permit No.
Basin 105

NOTICE OF INTENT NO. 28173

1. OWNER Richard & Elise Erickson
MAILING ADDRESS Mike Jarrett Construction, Gardnerville NV.
ADDRESS AT WELL LOCATION 468 Tycoon Ct.

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 12 N S R. 19 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 19-192-09 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Cobbles and Coarse Gravels		3	47	44
Coarse DG Sands and Granite Fractures		47	89	
Brown Sandy Clay		89	137	
Coarse DG Sands		137	155	
Fractured Granite and Granite Rusty Gravels	XX	155	180	

Date started 8-19, 1999
Date completed 8-21, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation Mill slot
Size perforation 3x3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 180' feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. 35+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling
Address 20 Kietzke Drive Carson City, NV 89706
Contractor

Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
By driller performing actual drilling on site or contractor
Date 8-30-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627