

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77112
 Permit No. 105
 Basin.....

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28175

1. OWNER DE Jansoo Construction ADDRESS AT WELL LOCATION 1349 View Pointe Cir Gardnerville NV 89410
 MAILING ADDRESS 1589 Sacramento Garden NV 89423
 2. LOCATION NE 1/4 NE 1/4 Sec 1 T 12 S R 20 E Douglas County
 PERMIT NO. 23-610-70 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan Clay		0	3	3
Cobbles and Gravels		3	39	36
Coarse Sands and Obsidian gravels		39	110	71
Brown Clay Seams and Brown Fine Sands		110	186	76
Coarse Sand with Small Clay Strata		186	225	39
Red Brown Clay		225	230	5
Fractured Gravels Obsidian Sands Coarse DC Sands	KXX	230	260	30

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.188</u>	<u>0</u>	<u>260</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 240 feet to 260 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100' feet to 200 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. 2.5 P.S.I.
 Water temperature Cold °F Quality Good

Date started 9-3, 1999
 Date completed 9-5, 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>35'</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Kit Kat Drive Carson City, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Heck
 By driller performing actual drilling on site or contractor
 Date 9-5-99