

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77113
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36786

1. OWNER Walter Burgess ADDRESS AT WELL LOCATION 1386 Hawkins Peak Rd Gardnerville, NV.
 MAILING ADDRESS P.O. Box 612 CORONA Del MAR CA 92625
 2. LOCATION NE 1/4 NE 1/4 Sec 1 T. 12 S R. 20 E Douglas County
 PERMIT NO. 23-483-22 Wildflower Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Br Clay & Boulders</u>		<u>0</u>	<u>17</u>	<u>17</u>
<u>SAND & GRAVEL</u>		<u>17</u>	<u>32</u>	<u>15</u>
<u>SANDY CLAY BR.</u>		<u>32</u>	<u>168</u>	<u>136</u>
<u>BR Clay</u>		<u>168</u>	<u>180</u>	<u>12</u>
<u>BR SANDY CLAY</u>		<u>180</u>	<u>212</u>	<u>32</u>
<u>GRAVEL (Med)</u>	<u>X</u>	<u>212</u>	<u>253</u>	<u>41</u>
<u>SANDY CLAY</u>		<u>253</u>	<u>260</u>	<u>7</u>
<u>Coarse SAND</u>	<u>X</u>	<u>260</u>	<u>280</u>	<u>20</u>

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>60</u>	<u>60</u>
<u>9 1/2</u>	<u>60</u>	<u>260</u>	<u>260</u>
<u>5 7/8</u>	<u>260</u>	<u>280</u>	<u>280</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>+2</u>	<u>260</u>
<u>5</u>	<u>10</u>	<u>1.88</u>	<u>260</u>	<u>280</u>

Perforations:
 Type perforation Factory Mill
 Size perforation 10 x 2 1/2 6 Row
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level: 192 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

Date started Aug 2 1999
 Date completed Aug 6 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc. Contractor
 Address 7780 CURRY Rd Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board: 27673 A
 Nevada driller's license number issued by the Division of Water Resources, the on-site ofiller: 1586
 Signed W. Megard
 By driller performing actual drilling on site or contractor
 Date 8-9-99

RECEIVED
 99 SEP -2 AM 11:47
 STATE ENGINEERS OFFICE