

OFFICE USE ONLY  
 Log No. 77114  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26827

1. OWNER Barry Lar A Jue ADDRESS AT WELL LOCATION 1344 View Point Cir. Gardnerville Nv. 89410  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec 1 T. 12 S R 20 E Douglas County  
 PERMIT NO. 23-610-170 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Cobbles and Boulders</u>		<u>4</u>	<u>63</u>	<u>59</u>
<u>Large Gravels and Sand</u>		<u>63</u>	<u>96</u>	<u>33</u>
<u>Brown Sand clay</u>		<u>96</u>	<u>115</u>	<u>9</u>
<u>Brown Clay and clay balls and small sands</u>		<u>115</u>	<u>186</u>	<u>71</u>
<u>Brown clay</u>		<u>186</u>	<u>200</u>	<u>14</u>
<u>Large obsidian Gravels and Fractures</u>	<u>XX</u>	<u>200</u>	<u>240</u>	<u>40</u>

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3x3/32  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 240 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature Cold °F Quality Good

Date started 8-6 1999  
 Date completed 8-8 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>35</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling  
 Address 20 Koi Kat Drive Carson Contractor 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed 9-8-99  
 By driller performing actual drilling on site or contractor  
 Date Michael J. Black