WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77121
Permit No.
Basin

NOTICE OF INTENT NO. 41356

1. OWNER Don Bauman
MAILING ADDRESS 10885 Reins Way
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 10885 Reins Way

2. LOCATION NE 1/4 NE 1/4 Sec. 31 T 35 N/S R 38 E Humboldt County
PERMIT NO. Issued by Water Resources | 10-627-11 Parcel No. | Rawhide Estate Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	4	
Gravel		4	12	8
Sand & gravel		12	56	44
Cobbles		56	70	14
Gravel & cobbles		70	95	25
Gravel, cobbles, sand		95	112	17
Coarse gravel		112	123	11
Sand & gravel w/cobbles		123	155	32
rock/cobbles		155	200	45
Cemented gravel & clay		200	230	30
cobbles		230	250	20
cobbles w/sand	x	250	300	50
sand & gravael	x	300	320	20
cobbles, gravel,	x	[illegible]		
sand-clay		320	364	44

Date started 6/15/99, 19__
Date completed 6/17/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 364 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	50	Feet
9-7/8	Inches	50	Feet	364	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	360

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3
From 280 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 96
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 96 feet to 364 feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154 T-1

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 6/25/99