


Sub 3036

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 77122
Permit No. 1295884
Basin 129



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4139

1. OWNER Robert & Myrtle Albrecht ADDRESS AT WELL LOCATION Coyate Creek Ranch
MAILING ADDRESS Star Rte
Imlay, NV 89418

2. LOCATION SW 1/4 NW 1/4 Sec. 15 T 30 N/S R 36 E Pershing Pershing County
PERMIT NO. 58841 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
shale, sand & gravel		0	30	30
rock, gravel - clay & sand		30	50	20
black rock, gravel & clay		50	70	20
fractured rock		70	84	14
rock w/s fractures		84	89	5
solid black rock		89	108	19
solid rock - black		108	129	21
solid rock w/few tiny fractures		129	184	55
rock w/moderate fractures		184	266	82

8. WELL CONSTRUCTION
Depth Drilled 266 Feet Depth Cased 260 Feet
HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 50 Feet
9-7/8 Inches 50 Feet 266 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	260

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3
From 160 feet to 260 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 266 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

Date started 7/27/99, 19
Date completed 7/29/99, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>20</u>		<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154 T-1
Signed Jean A. Tomp
By driller performing actual drilling on-site or contractor
Date 8/7/99