

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4256

1. OWNER Galina Water Enterprises
MAILING ADDRESS C/O Randy Bowling P.O. Box 12726 Reno, NV 89510 ADDRESS AT WELL LOCATION 4.5 miles west of highway 395 on Mount Rose Highway

2. LOCATION NW 1/4 SW 1/4 Sec 35 T 18 N S R 19 E Washoe County
PERMIT NO. 61267, 61268 APN 150-102-01 N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders/cobbles		0'	220'	220'
Little sand				
Dark basalt		220'	250'	30'
Little brown clay				
Dark basalt		250'	330'	80'
Some red cinders				
Dark basalt/ Brown sandy clay		330'	540'	210'
Dark basalt		540'	670'	130'
Some ash and wite clay				
Gray rock with gray ash		670'	685'	15'
Black porous basalt		685'	1000'	
Little ash/brown sandy clay			T.D.	

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4" To 0
Inches Feet 1000 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0	1000'
2"		Blank	+ 2'	454'
2"		Screen	454'	1000'

Perforations:
Type perforation Mill Slot
Size perforation .07
From 454' feet to 1000' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 100' feet to 1000' feet

9. WATER LEVEL
Static water level 281 feet below land surface
Artesian flow None G.P.M. _____ P.S.I. _____
Water temperature cool °F Quality _____

Date started June 6th, 1999
Date completed June 29th, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Airlift through			38 Total
2" casing. Could not be monitored.			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Company Contractor
Address 275 County Road 98 Contractor
Woodland, CA 95695
Nevada contractor's license number 0019101 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2013
Signed [Signature] By driller performing actual drilling on site or contractor
Date JULY 1, 1999