


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 77132  
 Permit No. X  
 Basin X

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **39847**



1. OWNER John Mondelli ADDRESS AT WELL LOCATION 162 Concho Dr.  
 MAILING ADDRESS 162 Concho Dr.  
Reno, NV 89511

2. LOCATION NE 1/4 SE 1/4 Sec. 7 T 17N N/S R 20E E Washoe County  
 PERMIT NO. WaCo#6400 050-112-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Sandy soil		2	5	3
Brown sand		5	15	10
Sand & gravel		15	18	3
Brown clay		18	25	7
Sand	x	25	40	15
Clay & Gravel		40	65	25
Sand & Gravels		65	75	10
Brown clay		75	95	20
Sand & Gravels	x	95	110	15
Clay & Gravels		110	122	12
Brown clay		122	135	13

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)  

10 5/8	Inches	From 0	Feet	To 135	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	135

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 x 3"

From	100	feet to	120	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Surface Seal:  Yes  No  
 Depth of Seal 100

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 135 feet

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

9. WATER LEVEL  
 Static water level 8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 8/6/99

Date started 7/27/99, 19\_\_\_\_  
 Date completed 7/30/99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
With pump	25	17	2 hrs
With air	75+		2 hrs