

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 00276

1. OWNER RANDY & ELISABETH WARNER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1805 Brenda Way 4770 Blazer Cir.
Carson City, Nevada 89704 Carson City, Nevada 89704

2. LOCATION SE 1/4 SE 1/4 Sec 5 T 16N N/S R 20 E Washoe County
 PERMIT NO. 050-302-27 New Washoe
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Med soft decomposed granite, some clay streaks		1	35	34
Rusty brown weathered granite		35	81	46
Weathered green granite		81	103	22
Weathered gray granite		103	111	8
Rusty brown soft zone (NO WATER)		111	112	1
Gray granite		112	135	23
Fracture (NO WATER)		135	136	1
Gray hard granite		136	201	65
Rusty soft zone (app 1 1/2 GPM)	X	201	203	2
Gray hard granite		203	316	113
White hard granite		316	335	19
Blue gray hard granite		335	381	46
Weathered hard granite		381	406	25
Fracture (app 3 GPM)	X	406	407	1
Weathered hard granite		407	420	13
Fracture	X	420	421	1
Weathered hard granite		421	450	29

8. WELL CONSTRUCTION
 Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 450 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>450</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 405 feet to 445 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 450 feet

9. WATER LEVEL
 Static water level: 93 feet below land surface
 Artesian flow _____ G.P.M. 17 P.S.I.
 Water temperature cold °F Quality clear

Date started 6-8-99 19____
 Date completed 6-11-99 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>17</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, Inc. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne G. Helmer
 By driller performing actual drilling on site or contractor
 Date June 16, 1999