

OFFICE USE ONLY  
 Log No. 77153  
 Permit No. 91  
 Basin.....  
 NOTICE OF INTENT NO. 40348

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MIKE CLARK ADDRESS AT WELL LOCATION 465 Leventina Canyon Road  
 MAILING ADDRESS 321 Broadway Blvd. Reno, Nevada 89523  
 2. LOCATION NE 1/4 NW 1/4 Sec. 22 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. R-350 038-673-10 Beli Ranch Area  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other.....  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil w/boulders		0	1	1
Granite Boulder		1	3	2
Boulders & gravels with brown clay		3	40	37
Brown sandy clay		40	120	80
Dark brown clay		120	145	25
Gray sandy clay		145	158	13
Soft zone (app 3 GPM)	X	158	162	4
Gray sandy clay		162	209	47
Soft zone (NO WATER)		209	212	3
Gray sandy clay		212	222	10
Soft zone (app 3 GPM)	X	222	238	16
Gray sandy clay		238	260	22
Soft zone	X	260	267	7
Gray sandy clay		267	291	24
Soft zone		291	293	2
Gray sandy clay		293	300	7

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 300 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 240 feet to 260 feet  
 From 280 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50 feet  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 106 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 22 P.S.I.  
 Water temperature cold °F Quality clear

Date started 7-9, 1999  
 Date completed 7-12, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>22</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date July 15, 1999