

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16557

1. OWNER Darby Neagle ADDRESS AT WELL LOCATION Segment 2 on
 MAILING ADDRESS _____
 2. LOCATION 1/4 TS 1/4 Sec. 10 T 21 N 8 R 2 E Clark County
 PERMIT NO. DCW 1108 Issued by Water Resources 161-10-407-003 Parcel No. Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt</u>		<u>0</u>	<u>3</u>	
<u>Calecho Gravel</u>		<u>3</u>	<u>8</u>	
<u>Sandy Clay</u>		<u>8</u>	<u>24</u>	
<u>Sand w/ gravel</u>		<u>24</u>	<u>26</u>	
<u>Clay w/ gravel</u>		<u>26</u>	<u>30</u>	

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 30
24 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation slot
 Size perforation 0.32
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 10 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 30 feet

9. WATER LEVEL
 Static water level 11 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GDC Contractor
 Address 536 E Mitchell Contractor
Dick's
 Nevada contractor's license number issued by the State Contractor's Board 30246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1968
 Signed W. Lane
 Date 11-6-99

Date started 11-3, 1999
 Date completed 11-3, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>1.5</u>	

