WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77185
Permit No.
Basin 162

NOTICE OF INTENT NO. 18018

1. OWNER Gordon Scott
MAILING ADDRESS P.O. Box 651
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
1890 W. Charleston Park Ave.
Pahrump, NV 89048

2. LOCATION SW ¼ SE ¼ Sec. 17 T. 20S N/S R. 53E E. Nye County
PERMIT NO. 35-601-51 (Issued by Water Resources) | 36-601-51 (Parcel No.) | File Map#083114, Parcel 4 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
White clay		4	18	14
Broken caliche		18	26	8
Hard caliche		26	34	8
Grey clay		34	60	26
Brown clay	x	60	108	48
Hard lime		108	112	4
Grey clay with hard streaks	x	112	160	48

DCNR/DWR Received NOV 16 1999 LAS VEGAS OFFICE

Date started 11-03-99, 19
Date completed 11-04-99, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	160

Perforations:
Type perforation Torch cut
Size perforation ½" wide x 8" long
From feet to feet
From feet to feet
From 120 feet to 160 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by (CBD) (By driller performing actual drilling on site or contractor)
Date 11-11-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627