

Log No. 77217
 Permit No. 108
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25126
40 N. Bybee Ln
Same

1. OWNER Steve Hurt ADDRESS AT WELL LOCATION 40 N. Bybee Ln
 MAILING ADDRESS 40 N. Bybee Ln
Yerington NV 89447
 2. LOCATION SW 1/4 NW 1/4 Sec. 35 T. 14 S R. 26 E. Lyon County
 PERMIT NO. 14-371-25 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	4	4
Coarse Sand-Gravel		4	22	18
Coarse Sand-Gravel-Rock		22	32	10
Fine to Coarse Sand-Gravel		32	54	22
Clay-Gravel-Rock		54	74	20
Coarse Sand-Gravel		74	102	28
Coarse Sand-Gravel-Clay		102	115	13
Coarse Sand-Gravel		115	125	10
Coarse Sand-Gravel-Clay Strata		125	175	50
Brown Clay		175	187	12
Coarse Sand-Gravel		187	192	5
Coarse Sand-Gravel-Clay		192	194	2
Brown Clay & Sand		194	204	10
Coarse Sand-Gravel	X	204	210	6
Coarse Sand-Gravel-Clay	X	210	219	9

8. WELL CONSTRUCTION
 Depth Drilled 219 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 0 Feet 219 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>219</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/32 X 3" X 6 Rows
 From 179 feet to 219 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 219 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

Date started 9-26, 1995
 Date completed 9-30, 1995

7. WELL TEST DATA

TEST METHOD	TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>20</u>	<u>5</u>	<u>1 HR</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Orden Bros Drilling Contractor
 Address 162 N. Bybee Ln Contractor
Yerington NV 89447
 Nevada contractor's license number 15646
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 634
 Division of Water Resources, the on-site driller
 Signed Log Orden
 By driller performing actual drilling on site or contractor
 Date 6-29-99