

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. 77221
 Permit No. _____
 Basin 105

NOTICE OF INTENT NO. 28172

1. OWNER Greg Davies Construction ADDRESS AT WELL LOCATION 770 Gansburg Crk. Gardnerville NV. 89410
 MAILING ADDRESS P.O. Box 22 Gardnerville NV. 89410
 2. LOCATION SE 1/4 NW 1/4 Sec. 36 T. 12 S R. 19 E Douglas County
 PERMIT NO. 19-440-12 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders and Cabbles		0	24	24
DB Sands and DB Rocks, & Cabbles		24	63	39
DB Sands and Brown Clay		63	89	26
DB Sands and Small Clay Balls		89	136	47
Fractured Granite Rocks and DB Gravels	XXX	136	160	24

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

8. CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 X 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

Date started 8/12, 1999
 Date completed 8-14, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>35</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
20 Kit Kat Drive
Carson City, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L. Heel
 By driller performing actual drilling on site or contractor
 Date 8-16-99

RECEIVED
 99 SEP - 1 PM 12:02
 STATE ENGINEERS OFFICE