

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 77233
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28171
 ADDRESS AT WELL LOCATION: 320 Hansen Lane
Carsonville NV 8940

1. OWNER: Betty Kanelos
 MAILING ADDRESS: Carsonville NV
300 Hansen Lane
 2. LOCATION: SW 1/4 SW 1/4 Sec 34 T. 13 S R. 19 E Douglas County
 PERMIT NO. 19-070-260
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dark Brown Top Soil		0	4	4
DC Sands w/ surface under	x	4	9	5
Grayish Gray Clay Sandy		9	36	27
DC Sands Small-Fine Rusty Sands		36	59	23
Rusty Clay		59	71	32
DC Sands Silty Sands		71	95	24
Brown Sandy Clay Rusty and Silty		95	139	44
Coarse DC Sands	ax	139	160	21

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 160 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal: 100' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100' feet to 160 feet

9. WATER LEVEL
 Static water level: Flows feet below land surface
 Artesian flow: 3 gpm G.P.M. P.S.I.
 Water temperature: Cold °F Quality: Good

Date started 8-5 1999
 Date completed 8-7 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30*</u>	<u>40</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Capital City Well Drilling
 Address: 20 Kit Kat Drive
Carson City, NV 89706
 Nevada contractor's license number issued by the State of Nevada: 41775
 Nevada driller's license number issued by the Division of Water Resources, the State of Nevada: 1905
 Signed: Michael Hack
 By driller performing actual drilling on site or contractor
 Date: 8-7-99