Page 1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77234
Permit No.
Basin 108

NOTICE OF INTENT NO. 25171

1. OWNER Lyon County - Elm Tree Cemetery
MAILING ADDRESS P.O. Box 1362
Fernley NV 89408
ADDRESS AT WELL LOCATION 81 MISSOURI LN.
Yerington NV. 89447

2. LOCATION NW 1/4 SE 1/4 Sec. 10 T. 11 N/S R. 25 E. Lyon County
PERMIT NO. 62833 Issued by Water Resources
12-401-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE cemetery
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Coarse Sand-Gravel-Few Rock (Fill)		3	32	29
Coarse Sand-Gravel-Few Rock-Clay		32	57	25
Coarse Sand-Gravel-Rock (Fill)		57	65	8
Coarse Sand-Gravel-Few Rock (Fill)		65	105	40
Clay-Gravel-Sand		105	120	15
Coarse Sand-Gravel-Clay		120	132	12
Clay-Gravel		132	134	2
Coarse Sand-Gravel-Rock (Fill)		134	137	3
Coarse Sand-Gravel-Clay		137	156	19
Coarse Sand-Gravel-Small Rock (Fill)		156	160	4
Coarse Sand-Gravel-Clay		160	182	12
Coarse Sand-Gravel	X	182	191	9
Coarse Sand-Gravel-Clay		191	198	7
Coarse Sand-Gravel	X	198	215	17
Coarse Sand-Gravel-Rock	X	215	219	4
Coarse Sand-Gravel	X	219	225	6
Next Page				

Date started 9-4, 1997
Date completed 9-15, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	50	185' AIR Line	8 HRS

8. WELL CONSTRUCTION
Depth Drilled 259 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	100 Feet
9 7/8 Inches		100 Feet	259 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	259

Perforations:
Type perforation Slotted
Size perforation 3/32 X 3" X 6 rows
From 259 feet to 259 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 259 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-15-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

Page 2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77234
Permit No.
Basin 108

NOTICE OF INTENT NO. 25771

1. OWNER Lyon County - Elm Tree Cemetery
MAILING ADDRESS P.O. Box 1362
Fernley NV 89408

ADDRESS AT WELL LOCATION 81 Missouri Ln.
Yerington NV. 89447

2. LOCATION NW ¼ SE ¼ Sec. 10 T. 11 N/S R. 25 E. Lyon County
PERMIT NO. 62833 Issued by Water Resources
12-401-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Cemetery
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand-Gravel-				
Clay		225	243	18
Coarse Sand-Gravel-				
Few Rock	X	243	253	10
Coarse Sand-Gravel-				
Rock	X	253	256	3
Coarse Sand-Gravel	X	256	258	2
Coarse Sand-Gravel				
Rock	X	258	259	1

Date started 9-4, 19 92
Date completed 9-15, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	50	185' AIR Line	3 HR

8. WELL CONSTRUCTION
Depth Drilled 259 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	100 Feet
9 7/8 Inches		100 Feet	259 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	259

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 rows
From 239 feet to 259 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 259 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N By Bee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 18646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-15-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627