WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

77438

OFFICE USE ONLY
Log No. 77438
Permit No.
Basin 162

NOTICE OF INTENT NO. 19068

1. OWNER Kevin Duty
MAILING ADDRESS 3080 E Gamebird Rd. Pahrump, NV 89048
ADDRESS AT WELL LOCATION 3080 E. Gamebird Rd.

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 20S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 41-231-07 (Parcel No.) Calvada Valley Unit 1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	25'	25'
caliche		25'	30'	5'
white clay		30'	55'	25'
caliche		55'	60'	5'
white clay		60	65'	5'
caliche		65'	70'	5'
white clay		70'	80'	10'
caliche		80'	90'	10'
white clay		90'	100'	10'
brown clay		100'	140'	40'

RECEIVED OCT 22 P 12:05 STATE ENGINEERS OFFICE

OCT 1999

Date started Oct. 14, 1999
Date completed Oct 18, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140'

Perforations:
Type perforation Saw Cut
Size perforation 1/8" x 3"
From 100' feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Rox Naillon Drilling
Address (Contractor) P.O. Box 265
Pahrump, Nevada 89041
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forrest LaRue (By driller performing actual drilling on site or contractor)
Date 10/18/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627