

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77439
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19070

1. OWNER Ray Wagner ADDRESS AT WELL LOCATION 5701 Vicki Ann Rd
 MAILING ADDRESS 5701 Vicki Ann Rd
Pahrump, NV 89041

2. LOCATION NW 1/4 SW 1/4 Sec 12 T 21.5 N/S R 53 E Nye County
 PERMIT NO. 44-551-14 Old Home Ranch Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|-------------|-------------|------------|
| <u>brown clay</u> | | <u>0'</u> | <u>5'</u> | <u>5'</u> |
| <u>white clay</u> | | <u>5'</u> | <u>30'</u> | <u>25'</u> |
| <u>caliche</u> | | <u>30'</u> | <u>35'</u> | <u>5'</u> |
| <u>white clay</u> | | <u>35'</u> | <u>55'</u> | <u>20'</u> |
| <u>brown clay</u> | | <u>55'</u> | <u>75'</u> | <u>20'</u> |
| <u>white clay</u> | | <u>75'</u> | <u>100'</u> | <u>25'</u> |
| <u>caliche</u> | | <u>100'</u> | <u>105'</u> | <u>5'</u> |
| <u>brown clay</u> | | <u>105'</u> | <u>115'</u> | <u>10'</u> |
| <u>caliche</u> | | <u>115'</u> | <u>125'</u> | <u>10'</u> |
| <u>white clay</u> | | <u>125'</u> | <u>140'</u> | <u>15'</u> |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6.625</u> | <u>4.33</u> | <u>.316</u> | <u>0</u> | <u>140</u> |

Perforations:
 Type perforation 5/8" cut
 Size perforation 1/8" x 3"
 From 100' feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 49 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started September 27 1999
 Date completed October 1 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Rox Maillon Drilling Contractor
 Address P.O. Box 265 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035704
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
 Signed Forrest La Rue
 By driller performing actual drilling on site or contractor
 Date October 12, 1999

RECEIVED
 99 OCT 18 AM 11:08
 STATE ENGINEER'S OFFICE

