WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7440
Permit No.
Basin 162

NOTICE OF INTENT NO. 19058

1. OWNER Alma Dickinson
MAILING ADDRESS 3051 Hardy Lane
ADDRESS AT WELL LOCATION 3051 Hardy Lane

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 20 N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 28-681-04 Subdivision Name Charleston Park Ranchos

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5'	5'
brown clay		5'	10'	5'
white clay		10'	25'	15'
brown clay		25'	45'	20'
caliche		45'	50'	5'
white clay		50'	70'	20'
brown clay		70'	110'	40'
caliche		110'	115'	5'
white clay		115'	125'	10'
green clay		125'	130'	5'
brown clay		130'	140'	10'

RECEIVED 99 OCT 18 AM 11:08 STATE ENGINEERS OFFICE

RECEIVED NOV 18 2000

Date started 8/16, 1999
Date completed 8/20, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.314	0	14

Perforations:
Type perforation Saw Cut
Size perforation 1/8" X 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140' feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling (Contractor)
Address P.O. Box 265 (Contractor)
Pahrump, Nevada 89041
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest Naillon (By driller performing actual drilling on site or contractor)
Date 10/12/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627