WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1" Book

OFFICE USE ONLY
Log No. 77442
Permit No.
Basin 162

NOTICE OF INTENT NO. 19072

1. OWNER Jim McHugh
MAILING ADDRESS 1830 Justine Ct
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 1830 Justine Ct
Pahrump, NV

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) | Parcel No. 36-471-64 | Subdivision Name Nye County

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0'	5'	5'
white clay		5'	15'	10'
caliche		15'	20'	5'
white clay		20'	50'	30'
brown clay		50'	60'	10'
green clay		60'	65'	5'
white clay		65'	95'	30'
caliche		95'	105'	10'
white clay		105'	130'	25'
brown clay		130'	140'	10'
caliche		140'	145'	5'
brown clay		145'	170'	35'

RECEIVED 99 OCT 18 AM 11:08 STATE ENGINEER'S OFFICE

Date started September 18, 1999
Date completed September 27, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	Feet	0 Feet	170 Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	170

Perforations:
Type perforation Saw cut
Size perforation 1/8" X 3"
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling (Contractor)
Address P.O. Box 265 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest Lake (By driller performing actual drilling on site or contractor)
Date October 12, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (OI-627)