WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77443
Permit No. 53104
Basin 162

1. OWNER Richard Torrence
MAILING ADDRESS P.O. Box 448
Pahrump, NV 89041

NOTICE OF INTENT NO. 19055
ADDRESS AT WELL LOCATION 921 E First St.
Pahrump, NV 89048

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 20 S N/S R. 53 E Nye County
PERMIT NO. 53104 Issued by Water Resources
35-342-04 Parcel No.
Golding Green Acres Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay / gravel		0'	5'	5'
brown clay		5'	20'	15'
gravel / clay		20'	25'	5'
clay		25'	30'	5'
clay & gravel		30'	45'	15'
clay		45'	70'	25'
gravel, clay		70'	75'	5'
gravel		75'	85'	10'
clay, gravel		85'	90'	5'
clay		90'	95'	5'
caliche		95'	100'	5'
clay		100'	110'	10'
clay, gravel		110'	115'	5'
caliche		115'	125'	10'
clay		125'	135'	10'
gravel		135'	140'	5'
caliche		140'	150'	10'
clay		150'	160'	10'

Date started July 17, 1999
Date completed July 21, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	155'

Perforations:
Type perforation Saw Cut
Size perforation 1/8" x 3"
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling Contractor
Address Box 265
Pahrump, NV 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue By driller performing actual drilling on site or contractor
Date August 10, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

10)-027