


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 77458

Permit No. \_\_\_\_\_

Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19807

1. OWNER **SMITH, NIMROD**  
 MAILING ADDRESS 5060 N LINDA  
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 5060 N LINDA

2. LOCATION SE 1/4 SE 1/4 Sec. 17 T 19S

N/S R 53E E NYE County

PERMIT NO. 27-311-41

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE

- Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

- Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	90	
GRAVEL	WB	90	100	10
CLAY		100	110	10
GRAVEL	WB	110	120	10
CLAY		120	127	7
SAND	WB	127	140	13
		140		

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10.25</u> Inches	<u>0</u> Feet	<u>140</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:

Type perforation **SAW CUT**

Size perforation 1/8 X 3

From <u>100</u> feet to <u>140</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal:  Yes  No

Seal Type:

Depth of Seal 50

Neat Cement

Placement Method:  Pumped

Cement Grout

Poured

Concrete Grout

Gravel Packed:  Yes  No

From 50 feet to 140 feet

9. WATER LEVEL

Static water level 67 feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**

Contractor

Address P.O. BOX 4220

Contractor



**PAHRUMP, NV. 89048**

Nevada contractor's license number issued by the State Contractor's Board **47333**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor

Date 11/15/99



Date started 11/8/99, 19\_\_\_\_  
 Date completed 11/12/99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift  
 Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)