



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18590

1. OWNER.....CLARK COUNTY PUBLIC WORKS..... ADDRESS AT WELL LOCATION..... 6300 RIO VISTA DR.
 MAILING ADDRESS..... 500 S. GRAND CENTRAL PKWY..... LAS VEGAS, NV.
 P.O. BOX 554000 LAS VEGAS, NV. 89155-4000.....
 2. LOCATION..... NE 1/4..... NE 1/4 Sec..... 27T..... 19 N/S R..... 60 E..... CLARK County
 PERMIT NO..... 125-27-..... 6300 RIO VISTA DR. LAS VEGAS
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandon 1 domestic well				
Well depth 590'				
Static 153'				
casing 8 5/8"				
Perforate casing from 580' to 324'. Very little to no resistance to perforating.				
Perforate from 325' to 40' casing felt fair to good tight area or breach in casing at 285'.				
Trimmie with 4" pipe approx. 15 1/2 yards of 27 sack slurry.				

8. WELL CONSTRUCTION
 Depth Drilled..... 590' Feet Depth Cased..... Feet
 HOLE DIAMETER (BIT SIZE)
 From To
Inches.....Feet.....Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal.....
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From.....feet to.....feet

9. WATER LEVEL
 Static water level..... 153' feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature..... °F Quality.....

Date started..... 10/25 1999
 Date completed..... 10/29 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name..... Fred B. Allen III Contractor
 Address..... 4847 S. VALLEY VIEW LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board..... 18916
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 1301
 Signed..... Fred B. Allen III By driller performing actual drilling on site or contractor
 Date.....

