

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77470
 Permit No. 162
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19793

1. OWNER **RAMIREZ, TOMMY** ADDRESS AT WELL LOCATION **4180 MAJESTIC**
 MAILING ADDRESS **4180 MAJESTIC**
PAHRUMP, NV 89048

2. LOCATION **SW** 1/4 **SE** 1/4 Sec. **24** T **19S** N/S R **52E** E **NYE** County
 PERMIT NO. 27-733-02 MAJESTIC ESTATES
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	72	
CALICHIE	WB	72	84	12
CLAY		84	100	16
CALICHIE	WB	100	114	14
CLAY		114	125	11
CALICHIE	WB	125	140	15
		140		

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 10.25 Inches To 0 Feet 140 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
 Type perforation **SAW CUT**
 Size perforation **1/8 X 3**

From <u>100</u> feet to <u>140</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

Date started 10/25/99, 19__
 Date completed 10/29/99, 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed Thomas D... By driller performing actual drilling on-site or contractor
 Date 11/9/99

