WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77473
Permit No.
Basin 162

NOTICE OF INTENT NO. **19846**

1. OWNER **AMERICAN BUILDERS**
MAILING ADDRESS **1951 REDROCK**
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION **1951 RED ROCK**

2. LOCATION **NE** 1/4 **NE** 1/4 Sec. **28** T **20S** N/S R **53E** E **NYE** County
PERMIT NO. _____ Issued by Water Resources
39-051-22 Parcel No.
CALVADA VALLEY Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	65	
CALICHIE	WB	65	80	15
CLAY		80	102	22
CALICHIE	WB	102	120	18
CLAY		120	132	12
CALICHIE	WB	132	140	8

DCNR/DWR Received NOV 1 1999 LAS VEGAS OFFICE

Date started **10/11/99**, 19__
Date completed **10/15/99**, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
Type perforation **SAW CUT**
Size perforation **1/8 X 3**
From **100** feet to **140** feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal **50**
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From **50** feet to **140** feet

9. WATER LEVEL
Static water level **62** feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
Address **P.O. BOX 4220** Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board **47333**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
Signed Thomas Dan
By driller performing actual drilling on-site or contractor
Date **11/8/99**

USE ADDITIONAL SHEETS IF NECESSARY