



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16935

1. OWNER Roderick & Camille Spenner ADDRESS AT WELL LOCATION N/A 4975 EDLA ST
MAILING ADDRESS 1416 Ingraham St. Las Vegas, Nev. 89101

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T. 19 N/S R. 60 E Clark County
PERMIT NO. 125-31-401-012 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Boulders		0	470	
Cemented Gravel		470	480	
Gravel & Boulders		480	605	
Gravel & Water	xx	605	620	
Cemented Gravel		620	650	
Gravel & Water	xx	650	655	
Gravel		655	695	
Gravel & Water	xx	695	700	
Cemented Gravel		700	740	
Gravel & Water	xx	740	800	

8. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
12 1/4	0	70		
8 3/4	70	800		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	75
SRD21 6"	RVC		+1	800

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row

From 740 feet to 780 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 70 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 58.5 feet below land surface
Artesian flow cool G.P.M. P.S.I.
Water temperature _____ °F Quality _____

Date started 9/29/99 19____
Date completed 10/11/99 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
Address 5360 Bonita Vista Las Vegas, Nev. 89149 Contractor

Nevada contractor's license number 10062 issued by the State Contractor's Board
Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller.

Signed V. H. Dimick
By driller performing actual drilling on site or contractor
Date 10-11-99

