WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77544
Permit No.
Basin 220

NOTICE OF INTENT NO. 18528

1. OWNER Clark County School District
MAILING ADDRESS 1700 Galleria Drive
Henderson, NV 89014

ADDRESS AT WELL LOCATION Bowler Elementary School, 1425 Whipple Rd., Logandale, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 26 T T15S N/S R R67E E Clark County
PERMIT NO. (Issued by Water Resources) 041-26-101-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.2	2
Silty sand with gravel		0.2	35	34.8
Silty sand with		35		
cobbles			36	1
Silty sand with gravel		36	75	39

Date started 8/17/1999, 19__
Date completed 8/17/1999, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	75 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	75

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-40'/Bentonite40-43
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 43 feet to 75 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1869
Signed (By driller performing actual drilling on-site or contractor)
Date 12/10/99

USE ADDITIONAL SHEETS IF NECESSARY