

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77551
 Permit No. _____
 Basin 218

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18533**

1. OWNER Nevada Power Company ADDRESS AT WELL LOCATION Reid Gardner Station, Moapa, NV
 MAILING ADDRESS 6226 West Sahara Avenue Las Vegas, NV 89102

2. LOCATION NE 1/4 SE 1/4 Sec. 7 T 15S N/S R 66E E Clark County
 PERMIT NO. 042-07-100-004 MW-3
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------|--------------|------|------|------------|
| Clayey silt | | 0 | 1 | 1 |
| Conglomerate | | 1 | 10.5 | 9.5 |
| Sandstone | | 10.5 | 17 | 6.5 |
| Conglomerate | | 17 | 41.5 | 24.5 |
| Claystone | | 41.5 | 59 | 17.5 |
| Conglomerate | | 59 | 61 | 2 |
| Claystone | | 61 | 70 | 9 |
| Conglomerate | | 70 | 78 | 8 |
| Claystone | | 78 | 80 | 2 |
| Sandstone | | 80 | 84 | 4 |
| Claystone | | 84 | 92 | 8 |
| Sandstone | | 92 | 142 | 50 |
| Claystone | | 142 | 155 | 13 |

8. WELL CONSTRUCTION
 Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)
 From To
6 Inches 0 Feet 155 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 2.375 | 0.64 | 0.154 | 0 | 155 |

Perforations:
 Type perforation Factory slot
 Size perforation 0.020

From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-100'(bent 100-120) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 120 feet to 155 feet

9. WATER LEVEL
 Static water level 146.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9/7/1999, 19____
 Date completed 9/7/1999, 19____

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|-----------------------------------|-------------------------------|--|--------------|
| | G.P.M. | | |
| <input type="checkbox"/> Bailer | | | |
| <input type="checkbox"/> Pump | | | |
| <input type="checkbox"/> Air Lift | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants Contractor
 Address 731 Pilot Road, Suite H Contractor
Las Vegas, NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589

Signed Don Wilson
 By driller performing actual drilling on-site or contractor
 Date 12/13/99