WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77559
Permit No.
Basin 212

NOTICE OF INTENT NO. 19472

1. OWNER Ann Sliman Plumlee
MAILING ADDRESS 4699 Industrial Rd. #201
Las Vegas, Nev. 89103

ADDRESS AT WELL LOCATION
Vacant

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 21S N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) 164-06-301-009 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Reddish Shale		0	30	
Yellowich Shale		30	33	
Red Shale		33	50	
Reddish Shale		50	85	
Reddish Clay		85	150	
Clay & Water	xx	150	155	
Clay		155	200	
Red & Green Shale		200	250	
Shale & Water	xx	250	260	
Shale		260	460	
Shale & Water	xx	460	480	
Shale		480	585	
Shale & Water	xx	585	610	

Date started 11/17/99, 19
Date completed 11/26/99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased 610 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	55 Feet
8 3/4	Inches	55 Feet	610 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6"	SRD-21	PVC	+1	610

Perforations:
Type perforation Factory
Size perforation 3/16 Sieve type
From 590 feet to 610 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 11-29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627