WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77588
Permit No.
Basin 212

NOTICE OF INTENT NO. 19660

1. OWNER AF CONSTRUCTION /PAUL FAULKNER
MAILING ADDRESS 3635 W. TRAIN AVE., #A
LAS VEGAS, NV 89103

ADDRESS AT WELL LOCATION CLARK CO. DETENTION
CENTER EXPANSION PARCEL#139-34-210-034
LAS VEGAS, NV

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. DW-1109 (Issued by Water Resources) 139-34-210-034 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 12 DEWATER WELLS | | | | |
| | | | | |
| Wells #1,2,3,4 & 9 | | | | |
| Sandy clay | | 0' | 7' | |
| Caliche | | 7 | 8 | |
| Green Sandy Clay | | 8 | 20 | |
| Caliche | | 20 | 25' | |
| Sandy Clay | | 25 | 30' | |

Date started 11/15, 1999
Date completed 11/15, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0' Feet | 30' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14" | 36.71 | .250 | 0' | 30' |
| | | | | |

Perforations:
Type perforation Machine sloted
Size perforation 250
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301 - T1
Signed (By driller performing actual drilling on site or contractor)
Date 12-3-99

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627