WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77022
Permit No.
Basin 230

X NOTICE OF INTENT No. 22335

1. OWNER NYE County
MAILING ADDRESS 1210 East Basin Rd Suite 106 Pahrump NV 89048
ADDRESS AT WELL LOCATION N/A
NC Washburn 1X

2. LOCATION NE ¼ SW ¼ Sec. 11 T. 15S N/S R. 49E E. NYE County

X PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium and Valley fill		0	658	
Two wells were set in this hole. The bottom well was cased 0 to 510 with 1½" sch 80 pvc with 30 feet of perforated casing at 450 to 480 then gravel packed back to 400 feet with 8-12 silica sand a cement seal was placed and second well was set 1½ sch 80 pvc from 0 to 353 with 20' perforated casing at 333 to 353. 8-12 silica sand was packed to 320 feet hole was filled back to surface with aqua Grout.				

Date started 12-1, 1998
Date completed 12-10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 658 Feet Depth Cased 510 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17" Inches	0 Feet	20 Feet
6¼ Inches	20 Feet	450 Feet
5⅞ Inches	450 Feet	658 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7"	20lb	.280	0	20
1½		Sch 80 PVC	0	510
1½		Sch 80 PVC	0	353

Perforations:
Type perforation slotted
Size perforation .020
From ____ feet to ____ feet
From 450 feet to 480 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From 333 feet to 353 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 354 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature 80 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JOEL CAMPBELL Contractor
Address 12030 E RIGGS RD Contractor
CHANDLER AZ
Nevada contractor's license number issued by the State Contractor's Board 1803
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1813
Signed ____ By driller performing actual drilling on site or contractor
Date 1-13-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627