

OFFICE USE ONLY  
 Log No. 77624  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18809

1. OWNER GORDON R. SCOTT ADDRESS AT WELL LOCATION 610 W MORGAN LANE  
 MAILING ADDRESS P.O. BOX 651 PAHRUMP NV 89041  
 2. LOCATION NE 1/4 SW 1/4 Sec 9 T. 20S N15 R. 53 E Nye County  
 PERMIT NO. 35-181-13 Issued by Water Resources Parcel No. 35-181-13 Subdivision Name CAJ VEGAS RANCHES UNIT D, LOT 100

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SURFACE</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>SOFT BROWN CLAY</u>		<u>4</u>	<u>24</u>	<u>20</u>
<u>HARD SOFT SHALE</u>		<u>24</u>	<u>30</u>	<u>6</u>
<u>SOFT BROWN CLAY</u>	<u>X</u>	<u>30</u>	<u>64</u>	<u>34</u>
<u>HARD PAN</u>		<u>64</u>	<u>69</u>	<u>5</u>
<u>SOFT BROWN CLAY</u>	<u>X</u>	<u>69</u>	<u>98</u>	<u>29</u>
<u>HARD PAN</u>		<u>98</u>	<u>106</u>	<u>8</u>
<u>BROWN CLAY</u>	<u>X</u>	<u>106</u>	<u>140</u>	<u>34</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>#17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation 3/4" WIDE x 8" LONG  
 Size perforation TAPER CUT  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level: 43 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12-8-99 19\_\_\_\_  
 Date completed 12-10-99 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>0 -</u>	<u>15 MIN</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Well Drilling Contractor  
 Address 1060 W Basin Rd Contractor  
PAHRUMP NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board: 7484  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 725  
 Signed Charles Nyberg By driller performing actual drilling on site or contractor  
 Date 12-15-99

