

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 776601
Permit No. _____
Basin. 012



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16562

1. OWNER Contel Const. Co. ADDRESS AT WELL LOCATION N. SIDE Broad Bent Rd E. LAS VEGAS.
MAILING ADDRESS 2650 N. Warrant Las Vegas NV 89115
2. LOCATION 1/4 Sec. 26 T. 21 N. 3 R. 62 E. Clark County
PERMIT NO. DW 4110 Issued by Water Resources Parcel No. 161-26-101-003 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>5</u>	
<u>Sand GRAVEL</u>	<u>5'</u>	<u>5</u>	<u>10</u>	
<u>GRAVEL</u>		<u>10</u>	<u>12</u>	
<u>Coliche</u>		<u>12</u>	<u>15</u>	
<u>Clay</u>		<u>15</u>	<u>30</u>	

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)
From 24" Inches 0 Feet 30 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>30</u>

Perforations:
Type perforation Slot
Size perforation 0.32"
From 10 feet to 30 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
Depth of Seal _____ Cement Grout.
Placement Method: Pumped Concrete Grout.
 Poured
Gravel Packed: Yes No #5
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.F.
Water temperature 60 °F Quality good

Date started 12-2- 1999
Date completed 12-2 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GRIFFIN DENATERING CORP. Contractor
Address 560 E. HAYLAND Contractor
ONTARIO Cal. 91761-3317
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed Edward J. Sainson
By driller performing actual drilling on site or contractor
Date 12-2-99

