WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77613
Permit No.
Basin 212

NOTICE OF INTENT NO. 19919

1. OWNER Kerr-McGee Chemical
MAILING ADDRESS 8000 W. Lake Mead Dr.
Henderson, NV 89015

ADDRESS AT WELL LOCATION Kerr-McGee Chemical
8000 W. Lake Mead Dr.
Henderson, NV 89015

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 22 N/S R. 62 E. Clark County
PERMIT NO. | Issued by Water Resources | 178-13-101-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Deive Pipe

6. LITHOLOGIC LOG TR-8

Material	Water Strata	From	To	Thickness
Sand, Silty Sand,				
Gravel		-0-	43	43
Silt		43	49	6
Sand, Sandy Gravel		49	93	43
Silt, Sandy Silt		93	98	5

RECEIVED 99 DEC 17 AM 11:22 STATE ENGINEER'S OFFICE

Date started September 29, 19 99
Date completed September 30, 19 99

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		45 min.

8. WELL CONSTRUCTION
Depth Drilled 98 Feet Depth Cased 93.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9-5/8 Inches	-0- Feet	98 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch 40	-0-	93.5

Perforations:
Type perforation Mill Slot
Size perforation
From 63 feet to 93 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 98 feet

9. WATER LEVEL
Static water level 52.8 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Stratton for Beylik Drilling
Contractor
Address 555 S. Harbor Blvd.
Contractor
La Habra, CA 90631-6124

Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011

Signed
By driller performing actual drilling on site or contractor
Date December 13, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627