WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77674
Permit No.
Basin 212

NOTICE OF INTENT NO. 19919

1. OWNER Kerr-McGee Chemical
MAILING ADDRESS 8000 W. Lake Mead Dr.
Henderson, NV 89015

ADDRESS AT WELL LOCATION Kerr-McGee Chemical
8000 W. Lake Mead Dr.
Henderson, NV 89015

2. LOCATION SE ¼ NW ¼ Sec. 13 T 22 N/S R 62 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 178-13-101-002 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Deive Pipe

6. LITHOLOGIC LOG TR-9

Material	Water Strata	From	To	Thickness
Sand, Silty Sand,				
Gravel		-0-	45	45
Sand, Gravel,				
(MC)		45	106	61
Silt, Sandy Silt		106	212	106
Gravel		212	250	38

RECEIVED 99 DEC 1 AM 11:22 STATE ENGINEER'S OFFICE

Date started October 06, 1999
Date completed October 07, 1999

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		60 min.

8. WELL CONSTRUCTION
Depth Drilled 250.5 Feet Depth Cased 250.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9-5/8 Inches		-0- Feet	250.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch 40	-0-	250.5

Perforations:
Type perforation Mill Slot
Size perforation 0.020
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 210
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 210 feet to 250.5 feet

9. WATER LEVEL
Static water level 64.0 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2011
Signed Donald Stratton
By driller performing actual drilling on site or contractor
Date December 13, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627