WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77678
Permit No.
Basin 212

NOTICE OF INTENT NO. 19919

1. OWNER Kerr-McGee Chemical
MAILING ADDRESS 8000 W. Lake Mead Dr.
Henderson, NV 89015

ADDRESS AT WELL LOCATION Kerr-McGee
8000 W. Lake Mead Dr.
Henderson, NV 89015

2. LOCATION NW ¼ SW ¼ Sec. 12 T. 22 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 178-12-401-004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Deive Pipe

6. LITHOLOGIC LOG TR-1

Material	Water Strata	From	To	Thickness
Sand, Slty Sd,				
Gravel		-0-	37	37
Silt, Sdy Silt,				
Clayey Silt, Clay		37	221	184
Silty Sand		221	236	15
Silt		236	259	23
Sand, Gravelly				
Sand		259	312	53

RECEIVED 99 DEC 17 AM 11:21 STATE ENGINEER'S OFFICE

DEC 21 1999

Date started September 01, 1999
Date completed September 03, 1999

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		.5

8. WELL CONSTRUCTION
Depth Drilled 312 Feet Depth Cased 312 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9-5/8 Inches	-0- Feet	312 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	SCH 40	-0-	311.5

Perforations:
Type perforation Slot
Size perforation .020
From 282 feet to 311.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 270
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 270 feet to 312 feet

9. WATER LEVEL
Static water level +4.2 feet below land surface
Artesian flow yes G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald Stratton (By driller performing actual drilling on site or contractor)
Date December 10, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627